Ridge and Valley Charter School

Education for a Hopeful Sustainable Future
1234 State Route 94
Blairstown, NJ 07825
(908) 362-1114 Fax: (908) 362-6680
email: office@ridgeandvalley.org **www.ridgeandvalley.org**

June 23, 2017

Dear Ridge and Valley Charter School Community,

Our school is committed to protecting student, families, and staff health. To be in compliance with the Department of Education regulations, we tested our schools' drinking water for lead.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Ridge and Valley Charter School and identified and tested all drinking water and food preparation outlets. All the samples tested were below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 ug/l [ppb], except for the utility sink in the Universe Building which resulted in a first draw result of 18.5 ug/1 [ppb]. The remedial action taken as approved by our Water System Operator, McGowan LLC Well Water Compliance Management, has been to install a filter on the faucet at the utility sink.

For More Information

A copy of the test results is available in the office for review by the public, including students, staff, and parents and are available on our website. For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Sincerely,

Nanci Dvorsky
Administrative Coordinator
Ridge and Valley Charter School

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602084.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #1
SAMPLE LOCATION: OFFICE RIGHT NS - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:41 PWS ID# NJ2106319

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.16	ug/l	15	6/5/17-09:41
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	Yes			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 370602085.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #2
SAMPLE LOCATION: OFFICE LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:44

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.04	ug/l	15	6/5/17-09:48
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602086.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #3
SAMPLE LOCATION: GALAXY LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825
DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:48

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.56	ug/l	15	6/5/17-09:55
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 370602087.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #4
SAMPLE LOCATION: GALAXY RIGHT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.96	ug/l	15	6/5/17-10:
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602088.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #5
SAMPLE LOCATION: UNIVERSE BUILDING FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:53

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	18.5	ug/l	15	6/5/17-10:10
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370602089.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #6
SAMPLE LOCATION: CONSTELLATION LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:57

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.12	ug/l	15	6/5/17-10:17
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370602090.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #7
SAMPLE LOCATION: CONSTELLATION RIGHT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:01

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	0.922	ug/l	15	6/5/17-10:24
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602090.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #7
SAMPLE LOCATION: CONSTELLATION RIGHT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:01

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	0.922	ug/l	15	6/5/17-10:24
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370602091.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #8
SAMPLE LOCATION: NOVA LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:07

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.71	ug/l	15	6/5/17-10:31
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602092.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #9
SAMPLE LOCATION: NOVA RIGHT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:09

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.13	ug/l	15	6/5/17-10:38
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602093.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #10
SAMPLE LOCATION: QUASAR LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.45	ug/l	15	6/5/17-10:46
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602094.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #11
SAMPLE LOCATION: QUASAR RIGHT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:14

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.73	ug/l	15	6/5/17-11:17
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602095.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #12
SAMPLE LOCATION: STARDUST LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825
DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.30	ug/l	15	6/5/17-11:24
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602095.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #12
SAMPLE LOCATION: STARDUST LEFT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.30	ug/l	15	6/5/17-11:24
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602096.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #13
SAMPLE LOCATION: STARDUST RIGHT FP - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:23

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	2.34	ug/l	15	6/5/17-11:45
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

REPORT # 370602097.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #14
SAMPLE LOCATION: OFFICE FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:38

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-11:53
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 370602098.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #15
SAMPLE LOCATION: GALAXY FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825
DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:47

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-12:00
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 370602099.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #16
SAMPLE LOCATION: UNIVERSE BUILDING FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825
DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-12:07
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370602100.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #17
SAMPLE LOCATION: CONSTELLATION FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 15:55

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-12:14
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370602101.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #18
SAMPLE LOCATION: NOVA FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:04

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-12:22
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

REPORT OF ANALYSIS

REPORT # 370602102.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #19
SAMPLE LOCATION: QUASAR FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:09

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-13:17
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 370602103.0
CLIENT # RID23N
DATE SUBMITTED: 6/2/2017

TO: Ridge and Valley Charter School
1234 Rt. 94

Blairstown NJ 07825
ATT: Nanci Dvorsky

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: #20
SAMPLE LOCATION: STARDUST FIELD BLANK - RIDGE AND VALLEY CHARTER SCHOOL, 1234 STATE RT. 94, BLAIRSTOWN, NJ 07825

DATE SAMPLED: 5/29/2017 TIME SAMPLED: 16:17

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<0.5	ug/l	15	6/5/17-13:10
Analytical Method	EPA 200.8			
Reporting Limit, ug/l	0.5			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

308574

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.